



Minutes of the Meeting
Board of Health
Tuesday, January 14th, 2024⁵

The meeting was called to order at 7:02 P.M.

The following members were present:

James Romano, Dan Fournier and Patrick McCrohan.

1. **Call to Order**

2. **120 Padelford Street**

The Septic Plans were reviewed by our consultant Gerald Bernard.

The Board reviewed the comments and the plans. The Board approved, stamped and signed. Plans given to Joe Malloch.

3. **3 Padelford Drive**

The Septic Plans were reviewed by our consultant Nyles Zager.

The Board reviewed the comments and the plans. Daniel Fournier made a motion to accept the following variances;

(1) To allow the S.A.S to be 17' from the rear property line, instead of the required 20'.

(2) To allow the base of the S.A.S to be 3.0' above the water table, instead of the required 5.0'.

(3) To allow the system to be designed for 100% of the Title 5 flow requirement, instead of the 150% requirement.

(4) To allow the base of the S.A.S to be 3.0' above the water table, instead of the required 4.0'.

Patrick McCrohan Sec- All in Favor. The Board approved, stamped and signed the plans; copies placed in folder.

4. **130 Myricks Street**

The Septic Plans were reviewed by our consultant Gerald Bernard.

The Board reviewed the comments and the plans. One of the comments asked if the Enviro-Septic Pipe is capable of withstanding H-20 loading? Per Nyles Zager the answer is "YES". The Board approved, stamped and signed the plans; copies placed in folder.

5. **44 Forrest Street**

The Septic Plans were reviewed by our consultant Gerald Bernard. The Board reviewed the comments and the plans. The Board approved, stamped and signed the plans; copies placed in folder.

6. **13 Elmwood Drive**

Tabled to next meeting.

7. **1 Haystack Lane**

The Board reviewed the As Built & the Sieve Test; copies placed in folder. The Board approved, stamped and signed the Certificate of Compliance.

8. **2 Demi Way**

The Board reviewed the Well Results; the Board signed; copy placed in folder.

9. **728 Berkley Street**

The Board reviewed the Well Results; copy placed in folder. The Board signed to filter and retest for Arsenic; yellow copy mailed to homeowner.

10. **1 Kellan Way (65R Seymour St)**

Mark Mello appeared before the Board with a letter for a Septic Plan extension. The Board reviewed; Dan Fournier made a motion to approve an extension until 2/22/2026 – Patrick McCrohan – Sec- All in Favor.

11. **66 Seymour Street**

Ed Harmon and Ray Francisco appeared before the Board with a letter requesting a Perc extension. Dan Fournier made a motion for 1 hole Perc Test – Patrick McCrohan – Sec – All in Favor.

The Board reviewed and accepted minutes, correspondence, signed invoices and permits.

Meeting ended at 8:38.

Next meeting scheduled meeting January 28th, 202~~4~~⁵. *sg*

James Romano
James Romano, Chairman

2/11/25
Date

Patrick McCrohan
Patrick McCrohan, Member

2-11-25
Date

Daniel Fournier
Daniel Fournier, Clerk

2/11/25
Date

